

No: C-187/19



o/o Station Officer
Fire & Rescue Station, Haripad
e-mail: hpd.frs@kerala.gov.in
Phone:0479-2411101, PIN:690548

Date: 06/07/2019

CERTIFICATE OF EXEMPTION FROM NOC

The application for certificate of exemption from NOC submitted to this Office by The Manager, ST. Thomas Central School, Karuvatta, Thottappally P O, Alappuzha District has been verified by me on 06/07/2019 regarding the building in Re Survey No.10/4 Karuvatta Village, Karthikappally Taluk, Alappuzha District, under the jurisdiction of Karuvatta Gramapanchayat.

The height of the Educational G+2 building is 12 Metres and the Ground Floor Plinth Area is 293.51 m² which are less than 15m and 1000 m² respectively and found to be exempted from Fire NOC as per KMBR/KPBR vide Gov. Orders F2-102/19 Home dtd.02/04/2019, GO(P) No:81/2017/LSGD dtd.31/10/2017, GO(P) No:82/2017/LSGD dtd.31/10/2017 and F2-9400/16 dtd. 16/04/2019, DG FRS HQ TVM under the "Ease of Doing Business" Policy.

Hence it is certified that the aforesaid building is exempted from acquiring NOC from Fire and Rescue Services Department as per the conditions prescribed in the orders cited above.



For *Sileepkumar*
ASTO
STATION OFFICER
FIRE & RESCUE STATION
HARIPAD

[Signature]

Principal
ST. Thomas Central School
Thottappally PO, Alappuzha
Dist. Alappuzha, Kerala, India